

DG Emission Control-latest Compliance by CAQM-76, dtd 29/9/23

S.No.	Fuel used by Generator	Diesel Generator's Capacity-KW(KVA)	What to do	DG run Instructions during GRAP (Oct-Feb)	DG run Instructions during Non GRAP (Mar-Sep)	Refer	Special Instructions	Date of Applicability
						CAQM-76/CPCB instructions		
1	LPG/PNG/Propane/Butane	Any capacity	Nothing	24 Hrs. NO Restriction	24 Hrs. No Restriction	CAQM Dir-76	NIL	01-10-2023
2	Diesel	Below 19KW (<23.75 KVA)	Nothing as no means available	No permission (Only in Emergency)	24 Hrs.	CAQM Dir-76	only in emergency during GRAP	01-10-2023
3	Diesel	19KW- < below 125KW (23.75kva-<156.25kva)	Dual Fuel system	24 Hrs. NO Restriction	24 Hrs. NO Restriction	CAQM Dir-76	If Gas infra is not available- then permitted only for emergencies	01-10-2023 (For Emergency services(one time exception) -Till 31/12/23
4	Diesel	125KW- <800KW (156kva-<below 1000Kva)	Dual Fuel System or RECD	24 Hrs. NO Restriction	24 Hrs. NO Restriction	CAQM Dir-76		01-10-2023 (For Emergency services(one time exception) -Till 31/12/23
5.	Diesel	800KW & Above (1000KVA and above)	Any System	24 Hrs.	24 Hrs.	CAQM Dir-76	Meet emission norms i.e. PM-<50mg/M3 CO<100mg/M3 Nox<650mg/M3	01-10-2023 (For Emergency services(one time exception) -Till 31/12/23